



# TYPE APPROVAL CERTIFICATE

Certificate No:  
**TAF0000067**  
Revision No:  
**1**

## This is to certify:

**That the Class A and B Penetration**

with type designation(s)  
**Roxtec Sleeve-it Fire penetration seal**

Issued to

**Roxtec International AB**  
**Karlskrona, Sweden**

is found to comply with

**DNV GL class programme DNVGL-CP-0165 – Type approval – Cable and pipe penetrations**  
**DNV GL rules for classification – Ships**  
**DNV GL offshore standards**

## Application :

**Approved for use as pipe, Spiro-duct penetration system in class B-15 bulkheads**  
**(see restrictions under application/limitation).**

**This certificate is recognized by Transport Canada.**

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.**

Issued at **Høvik** on **2021-06-07**

for **DNV**

This Certificate is valid until **2026-06-06**.

DNV local station: **Gothenburg FIS**

Approval Engineer: **Helge Bjørnarå**

**Sverre Olav Bergli**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



## Product description

“Roxtec Sleeve-It Fire penetration seal”

The pipe penetration system is made of collar casing housing different numbers of 60 mm wide layers of Sleeve-It graphite intumescent material (2.5 thick Intumex L or 2 mm thick TRP 345). The collars are fixed by bolt and nuts through B-class bulkhead made without steel plates on both sides and fixed by steel screws in common B-class bulkhead with steel plates on both sides.

Pipe collar types:

- “Sleeve-It Spiral Collar”, composed of two tubular casing (60 mm or 120 mm long) made of 0.7 mm thick mild steel welded on both side of a continuous 3 mm thick flange.
- “Sleeve-It Fire Collar (MAR)”, composed of 60 mm long tubular casing of 0.7 mm thick stainless steel with one break in the casing, welded to a splitted 3 mm thick flange (3 mm thick), bolted with bolt and nuts through the bulkhead.

For further details see approved drawings listed below.

### A – Plastic pipe penetration

Pipe material	Pipe outer diameter [mm]	Collar	Intumescent Material / Layers	Fitting of fire collar to bulkhead	Fire rating
PE, PB, PPr, uPVC	125	Fire Collar (MAR)	Intumex L / 5	Either side	B-15
Georg Fischer Multilayer Pipe (Pe/Alu)	16 - 32	Fire Collar (MAR)	TRP 345 / 3 <sup>1)</sup>	Either side	B-15
“Valsir” PVC pipe	20	Fire Collar (MAR)	TRP 345 / 3	Unexposed side	B-15
uPVC	16	Fire Collar (MAR)	TRP 345 / 2 + Sleeve-It putty (red)	Unexposed side	B-15
PPr	16	Fire Collar (MAR)	TRP 345 / 3	Unexposed side	B-15

1) for 16 mm pipe, 2 layers may be used.

### B – Steel spiral pipe penetration

Pipe material	Pipe outer diameter [mm]	Collar	Intumescent Material / Layers	Fitting of fire collar to bulkhead	Fire rating
Spiral steel pipe (Spiro duct)	250	Spiral Collar	Intumex L / 8	Either side	B-15
Spiral steel pipe (Spiro duct)	100	Spiral Collar	Intumex L / 4	Either side	B-15

PB = Polybutylene, PPr = Polypropylene, PE = Polyethylene, uPVC = unplasticized polyvinyl chloride, ABS = Acrylonitrile Butadiene Styrene

## Application/Limitation

Approved for use as pipe, Spiro-ducts penetration system in class B-15 bulkheads.

Each product is to be supplied with its manual for installation and maintenance.

## Type Approval documentation

Certification in accordance with Class Programme DNVGL-CP-0338, September 2018.

Test report No. VTT-S-5026-10 dated 10 February 2011 from VTT, Espoo, Finland.

Statement No. VTT-S-6599-10 dated 27 August 2010 from VTT, Espoo, Finland.

Statement No. VTT-S-1678-11 dated 15 March 2011 from VTT, Espoo, Finland.

Drawing No. SLV 324 DNV dated 20 March 2011 from Sleeve-IT Fire System Ltd.

## Tests carried out

Tested according to IMO FTP Code Part 3 (IMO Res. A. 754(18)) and in compliance with IMO 2010 FTP Code Ch. 8.

## Marking of product

The product is to be marked with name of manufacturer, type designation and fire-technical rating.



Job Id: 262.1-016326-6  
Certificate No: TAF0000067  
Revision No: 1

### **Transport Canada Approval**

Based on the procedures laid down in the Transport Canada Publication entitled "Approval Procedures for, Life Saving Equipment and Structural Fire Protection Products (TP 14612)", DNV confirms that the products listed in this certificate are in accordance with Transport Canada's requirements.

### **Periodical assessment**

DNV's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in DNVGL-CP-0338 Section 4.