



Marine & Offshore

Certificate number: 40893/B1 BV File number: ACI4000/032/009

Product code: 5300H

This certificate is not valid when presented without the full attached schedule composed of 7 sections

www.veristar.com

TYPE APPROVAL CERTIFICATE

This certificate is issued to

ROXTEC International AB

KARLSKRONA - SWEDEN

for the type of product

PIPE, CABLE, DUCT PENETRATIONS IN FIRE DIVISIONS

ROXTEC cable sealing system with multidiameter technology Jet Fire Application for S-Series Frames and RS-Series Seals (certified products, frame position and achieved performances - see §1)

Requirements:

Bureau Veritas Rules for the Classification of Offshore units Part C Chapter 4 ISO 22899-1

This certificate is issued to attest that Bureau Veritas Marine & Offshore did undertake the relevant approval procedures for the product identified above which was found to comply with the relevant requirements mentioned above.

This certificate will expire on: 12 Apr 2026

For Bureau Veritas Marine & Offshore, At BV GOTHENBURG, on 24 Nov 2023, Hans-erik ERICSSON

This certificate was created electronically and is valid without signature



This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with Bureau Veritas Marine & Offshore. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. This certificate is issued within the scope of the General Conditions of Bureau Veritas Marine & Offshore available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas Marine & Offshore for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

Certificate number: 40893/B1 BV

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION:

ROXTEC cable sealing system with multidiameter technology

1.1 - Roxtec S series frames

Consisting of Roxtec S series frame (S, SO, SF, SFO, SR, SK, SRC r20&r40 and SBTB), welded or bolted on to the Jet Fire steel division, and filled with Roxtec (standard, Ex or EMC, PE, ES, BG, BGB) halogen free insert modules. Assembled with Roxtec Wedge kit or Roxtec EMC, EX Wedge kit.

Additional insulation on penetrations and/or cables:

- should be approved as having the same level of performance as the penetrated division and expected classification of penetration,
- is to be fitted as shown in the referred Manufacturer's drawings (see §2.1) and also according to Manufacturer's insulation guidelines.

Penetration	Max.	Min. frame	Classification	Frame position Max. cable diameter		Max.
designation	external	depth			Pipe outer diameter	filling
	dimensions	(mm)			range	ratio
	(mm)					
S-series SK	596x271	200	When installed/insulated according drawing N° S1501671 rev. B dated	Unexposed	Cables, incl. Metal	39.3%
1x1 up to			24/08/2015 (detail J-30), the penetration can withstand the jet fire		Clad (MC) and Steel	
8+8x2			(250 kW/m²) for 30 min.		Wire Armored (SWA)	
					cables	
			When installed/insulated according drawing N° S1501671 rev. B dated	Unexposed	≤ 103 mm	
			24/08/2015 (detail J-60), the penetration can withstand the jet fire			
			(250 kW/m²) for 60 min.			
S-series	298x141	300	When installed/insulated according drawing N° S1577491 rev. A dated	Any	Cables Ø ≤ 90 mm	20.6%
SBTB 1x1			14/03/2022 (N°1), the penetration can withstand with regards to integrity		Steel pipes Ø 6-30 mm	
up to 8x1			only the jet fire (250 kW/m²) for 180 min.			
			Restricted application: exposed side of frame and division is the side			
			coated with passive fire protection.			
S-series	298x141	300	When installed/insulated according drawing N° S1577491 rev. A dated	Any	Cables Ø ≤ 77 mm	16.2%
SBTB 1x1			14/03/2022 (N°2), the penetration can withstand with regards to integrity		Steel pipes Ø 6-30 mm	
up to 8x1			only the jet fire (250 kW/m²) for 180 min.			
S-series	596x141	300	When installed/insulated according drawing N° S1501671 rev. B dated	Unexposed	Cables $\emptyset \le 43 \text{ mm}$	7.5%
SBTB 1x1			24/08/2015 (detail J-60 SBTB), the penetration can withstand the jet fire		Steel pipes Ø 20 mm	
up to 8+8x1			(250 kW/m²) for 60 min.			
S-series	296x532	400	When installed/insulated according drawing N° S1501671 rev. B dated	Unexposed	Cables $\emptyset \le 79 \text{ mm}$	13.2%
SBTB 1x1			24/08/2015 (detail J-120 SBTB), the penetration can withstand the jet fire		Steel pipes Ø 10-30	
up to 8x4			(250 kW/m²) for 120 min.		mm	
S-series	298x271	400	When installed/insulated according drawing N° S1558321 rev.C dated	Any	Cables $\emptyset \le 83 \text{ mm}$	12.7%
SBTB 1x1			15/03/2022 (N°1), the penetration can withstand with regards to integrity			
up to 8x2			only:		Steel pipes Ø 6-30 mm	
			- the HHF jet fire (350 kW/m²) for 20 min,		1 1	
			- the extended pool fire (250 kW/m²) for 35 min.			
S-series	298x271	400	When installed/insulated according drawing N° S1558321 rev.C dated	300 mm	Cables $\emptyset \le 83 \text{ mm}$	12.7%
SBTB 1x1			15/03/2022 (N°2), the penetration can withstand with regards to integrity	exposed side /	Steel pipes Ø 6-30 mm	
up to 8x2			only:	100 mm		
			- the HHF jet fire (350 kW/m²) for 20 min,	unexposed side		
			- the extended pool fire (250 kW/m²) for 10 min.			
S-series	238x532	300	When installed/insulated according drawings N° S1558321 rev.C dated	Unexposed	Cables Ø ≤ 83 mm	10.0%
SBTB 1x1			15/03/2022 (N°3), the penetration can withstand with regards to integrity		Steel pipes Ø 6-30 mm	
up to 6x4			only:			
			- the HHF jet fire (350 kW/m²) for 15 min,			
			- the jet fire (250 kW/m²) for 30 min,			
	220 525	200	- the extended pool fire (150 kW/m²) for 75 min.		G 11	10.50
S-series	238x532	300	When installed/insulated according drawings N° S1558321 rev.C dated	Unexposed	Cables Ø ≤ 90 mm	10.7%
SBTB 1x1			15/03/2022 (N°4), the penetration can withstand with regards to integrity		Steel pipes Ø 6-30 mm	
up to 6x4		1	only:			
			- the HHF jet fire (350 kW/m²) for 15 min,			
			- the jet fire (250 kW/m²) for 20 min.			

Following on next page

Certificate number: 40893/B1 BV

Penetration	Max.	Min. frame	Classification	Frame position	Max. cable diameter /	Max.
designation	external	depth			Pipe outer diameter	filling
	dimensions	(mm)			range	ratio
	(mm)					
S-series	296x532	400	When installed/insulated according drawing N° S1558323 rev. B dated	Any	Cables $\emptyset \le 83 \text{ mm}$	6.2%
SBTB 1x1			14/03/2022 (N°1), the penetration can withstand:		Steel pipes	
up to 8x4			- the HHF jet fire (350 kW/m²) for 30 minutes,		Ø 6-30 mm	
			- the extended pool (250 kW/m²) for 30 minutes.			
			Restricted application: exposed side of frame and division is the side			
			coated with passive fire protection.			
S-series	238x532	370	When installed/insulated according drawing N° S1558323 rev. B dated	Any	Cables $\emptyset \le 49 \text{ mm}$	16.0%
SKFOH 1x1			14/03/2022 (N°2), the penetration can withstand HHF jet fire (350 kW/m²)		Steel pipes	
up to 6x4			for 60 min.		Ø 16 mm	
			Restricted application: exposed side of frame and division is the side			
			coated with passive fire protection.			
S-series	238x532	370	When installed/insulated according drawing N° S1558323 rev. B dated	Any	Cables $\emptyset \le 49 \text{ mm}$	16.0%
SKFOH 1x1			14/03/2022 (N°3), the penetration can withstand:		Steel pipes	
up to 6x4			- the HHF jet fire (350 kW/m²) for 20 minutes,		Ø 16 mm	
			- the pool fire (200 kW/m²) for 40 minutes.			
			Restricted application: exposed side of frame and division is the side			
			coated with passive fire protection.			

1.2 - Roxtec RS seals

Composed of steel sleeves (welded or bolted) with RS-type (Ex and EMC versions included) halogen free rubber seals mounted in steel deck and bulkheads.

Additional insulation on penetrations and/or cables:

- should be approved as having the same level of performance as the penetrated division and expected classification of penetration,
- is to be fitted as shown in the referred Manufacturer's drawings (see §2.1) and also according to Manufacturer's insulation guidelines.

Penetration designation	External dimensions (mm)	Sleeve depth (mm)	Classification	Sleev position	Pipe outer diameter range
RS-series 23 up to 400 (back-to-back installation)	Ø32 to 414		When installed/insulated according drawing N° S1501673 rev. B dated 24/08/2015, the penetration can withstand the jet fire (250 kW/m²) for 60 minutes.	Unexposed	Steel pipes Ø≤324 mm

2. DOCUMENTS AND DRAWINGS:

As per the Manufacturer's insulation drawings quoted in tables in §1.

3. TEST REPORTS:

- 3.1 Test report N° 846031.02 dated 04/11/1997, as per Health and Safety Executiv, Offshore Technology Report OTI 95 634 "Jet Fire Resistance Test of Passive Fire Protection Materials", from SINTEF, Norway.
- 3.2 Test report N° NBL-107332 dated 03/06/2005, as per Health and Safety Executiv, Offshore Technology Report OTI 95 634 "Jet Fire Resistance Test of Passive Fire Protection Materials", from SINTEF, Norway.
- 3.3 Test report N° NBL-F10106 dated 13/10/2010, as per ISO 22899-1:2007, from SINTEF, Norway.
- 3.4 Test report N° NBL-F10107 dated 15/11/2010, as per ISO 22899-1:2007, from SINTEF, Norway.
- 3.5 Study report N° F15 20119-1 Version 1, "Evaluation of jet fire attack direction on response of products", dated 29/01/2015, from SP Fire Research AS, Norway (technical justification for worst case scenario being horizontal jet fire test).
- 3.6 Test report N° 120000-56 Version 1, "Sequential HHF jet fire test and "extended pool fire" test", dated 09/12/2019, from RISE, Norway.
- 3.7 Test report N° F17 120000-15:2 Version 1, "Jet fire test based on ISO 22899-1", dated 06/07/2017, from RISE, Norway.
- 3.8 Test report N° F19 120000-48:1 Version 1, "Jet fire test based on ISO 22899-1", dated 11/04/2019, from RISE, Norway.
- 3.9 Test report N° F19 120000-48:2 Version 1, "Jet fire test based on ISO 22899-1", dated 11/04/2019, from RISE, Norway.
- 3.10 Test report N° 120000-59 Version 2, "Sequential HHF jet fire test, "standard" jet fire test and "pool fire" test", dated 17/08/2020, from RISE, Norway.
- 3.11 Statement N° 120000-81 on results in test reports N° F17 120000-15:2 Version 1 and N° F19 120000-48:1 Version 1, dated 04/03/2022, from RISE, Norway.

Certificate number: 40893/B1 BV

- 3.12 Test report N° 120000-70 Version 1, "Jet fire test based on ISO 22899-1", dated 18/05/2021, from RISE, Norway.
- 3.13 Test report N° 120000-67 Version 1, "Sequential HHF jet fire test and "extended pool fire" test", dated 05/10/2020, from RISE, Norway.

4. APPLICATION / LIMITATION:

- 4.1 Approved for use as cable transits in jet-fire resistant steel divisions with limitations contained in §1.
- 4.2 **Restricted application (refer to §1 for concerned cable penetration systems):** the use of cable penetration systems in bulkhead or deck is restricted to application where on board fire hazard has been identified as being from the bulkhead's or deck's insulated side.
- 4.3 For S-Series including cables, filling ratio not to exceed the one tested (see § 1).

5. PRODUCTION SURVEY REQUIREMENTS:

- 5.1 The **ROXTEC cable sealing system with multidiameter technology, S-series and RS-series** are to be supplied by **ROXTEC International AB** in compliance with the type described in this certificate.
- 5.2 This type of product is within the category HBV of Bureau Veritas Rule Note NR320 and as such does not require a BV product certificate.
- 5.3 **ROXTEC International AB** has to make the necessary arrangements to have its works recognised by Bureau Veritas in compliance with the requirements of NR320 for HBV products.
- 5.4 For information, **Roxtec International AB** has declared to Bureau Veritas the following production site(s):

ROXTEC International AB Rombvägen 2 371 23 KARLSKRONA SWEDEN

6. MARKING OF PRODUCT:

The product or packing is to be marked with Manufacturer name, type, designation and fire-technical rating.

7. OTHERS:

- 7.1 It is **ROXTEC International AB**'s responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.
- $7.2 \text{ This Certificate supersedes the Type Approval Certificate } N^{\circ} \ 40893/B0 \ BV \ issued \ on \ 12/04/2021 \ by \ the \ Society.$
- 7.3 Testing for water and gas tightness witnessed by third party (DNV):

Product	Report N°	Date
SLFO/RI	MLM090673	08/10/2009
Bolted sleeve	MLM020401	25/03/2002
S-frame	MLM020400	25/03/2002
S-frame	SKM-04-4088	16/06/2004
RS-seal	MLM090652	15/06/2009

Product	Test pressure water tightness	Test pressure gas tightness
S Series frame	6 bar	3 bar
RS Series seal	6 bar	3 bar
Welded SL, SLF sleeve and frame	6 bar	3 bar
Bolted SLF sleeve and frame	5 bar	2.5 bar
SLFO/RI sleeve	2 bar	1 bar

*** END OF CERTIFICATE ***