



Confirmation of Product Type Approval

Company Name: ROXTEC INTERNATIONAL AB

Address: ROMBVAGEN 2 LYCKEBY SE 371 65 Sweden

Product: Penetration Device for Bulkhead and Deck Firetight and Watertight Penetrations

Model(s): Roxtec R Series Frames

Endorsements:

Certificate Type	Certificate Number	Issue Date	Expiry Date
Product Design Assessment (PDA)	19-LD1837304-PDA	18-JUN-2019	17-JUN-2024
Manufacturing Assessment (MA)	24-6227546	25-JAN-2024	08-JAN-2029
Product Quality Assurance (PQA)	NA	NA	NA

Tier

3 - Type Approved, unit certification not required

Intended Service

Multi and Single pipe and cable penetrations in Class H-60/-120 bulkheads and decks. Penetrations of watertight and gastight steel bulkheads and decks up to the specified pressure.

Description

"Roxtec pipe and cable sealing system with multidiameter technology" composed of steel sleeves (welded or bolted) with R & RO type (EMC versions included) halogen free rubber frames in size 50-200, and filled with Roxtec halogen free insert modules, mounted in steel decks or bulkheads.

Ratings

H-60/-120 Decks for Steel Pipes and Cables

H-60/120 Bulkheads for Steel Pipes

H-60 / 120 Bulkheads for R50 with Cables

H-60 Bulkheads for R70- R200 with Cables

Watertight test pressure 6 bar (except bolted versions test pressure at 5 bar)

Gastight test pressure 4 bar (except bolted versions test pressure at 2.5 bar)

Service Restrictions

a) Maximum tested Marine cable diameter: 88 mm and maximum tested steel pipe outside diameter 51 mm

b) For cables and pipes penetration on H60/ H120 bulkheads, fire is to be from insulated side only.

- b) Maximum frame size tested : Size 200
- c) Minimum frame size tested: Size 50
- d) Not to be used in tank boundaries.
- e) Tested with Marine Power/ Instrumentation/Control Cables.
- f) Insulation material is to be H-60/-120 approved type and installed in accordance with the manufacturer's ABS approved installation drawings S1540305 Rev A , S1540306 Rev A, S1014912 Rev A, S1014914 Rev A (as applicable to the division) to the satisfaction of the Surveyor.
- g) Unit Certification is not required for this product. If the manufacturer or purchaser request an ABS Certificate for compliance with a specification or standard, the specification or standard, including inspection standards and tolerances, must be clearly defined.

Comments

- a) All seal type should be installed in accordance with the manufacturers instructions in accordance with ABS approved installation drawings.
- b) Watertight or fire rated bulkheads or decks for cable penetrations are to be examined and tested as per ABS Marine Vessels Rules 3-7-1/Table1 and 4-8-4/29.15.
- c) When requested to be used in watertight bulkheads on passenger ships or special purpose ships, the penetration system has to comply with the requirements given in SOLAS Ch. II -1 Reg. 13.2.3 (Consolidated Edition 2014). This approval of penetrations passing through watertight bulkhead is not to be construed as a substitute for flag Administration's approval for the purpose of SOLAS (Consolidated Edition 2014).
- d) The product or packing is to be marked with name of manufacturer, type designation and fire rating.
- e) The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product.

Notes, Drawings and Documentation

SP Fire Test Report Numbers P601739, P601740 both dated 28 June 2006

CTO Fire Test Report Numbers RS-19-B-036-E & RS-19-B-037-E both dated 21 March 2019

SWRI Fire Test Report Number 01.24214.01.002 dated 14 February 2019

DNV Inspection Report Nos.:MLM 010238 (30 August 2001) , MLM 010247 (dated 28 September 2001)

Insulation/Installation drawings No:

Drawing No. S1540305, Revision: A- Deck/ Bulkhead H-120, Cables

Drawing No. S1540306, Revision: A,- Deck/ Bulkhead H-60, Cables

Drawing No.S1014912, Revision: A- Deck/ Bulkhead H-60, Pipes

Drawing No. S1014914, Revision: A- Deck/ Bulkhead H-120, Pipes

Term of Validity

This Product Design Assessment (PDA) Certificate 19-LD1837304-PDA, dated 18/Jun/2019 remains valid until 17/Jun/2024 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in

existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

ABS Rules

2019 ABS Marine Vessels Rules 1-1-4/7.7, 1-1-A3, 1-1-A4, 4-6-2/9.7, 4-8-4/21.13, 4-8-4/29.15

2019 ABS Facilities on Offshore Installations Rules 1-1-4/9.7, 1-1-A2, 1-1-A3 and 3-8/9.13, 3-8/9.15

2019 ABS Mobile Offshore Unit Rules 1-1-4/9.7, 1-1-A2, 1-1-A3, 4-2-1/11.15, 4-3-3/5.13.1, 5-1-1/3.5

International Standards

IMO 2010 FTP Code (2012 Edition) , Annex 1, Part 3 with Norwegian Petroleum Directorate H Class Temperature Curve

EU-MED Standards

NA

National Standards

Acts, Regulations and Provisions for the Petroleum Activities, Volume 2, Norwegian Petroleum Directorate, Issue June 1, 1999- For H Class Temperature Curve

Government Standards

This PDA conforms to Transport of Canada requirements as per Transport Canada Policy Letter A8706-1 RDIMS#1961446.

Other Standards

NA



A handwritten signature in blue ink, appearing to read 'Joseph W. ...', is written over the printed name and title.

Corporate ABS Programs
American Bureau of Shipping
Print Date and Time: 13-Feb-2024 12:50

ABS has used due diligence in the preparation of this certificate, and it represents the information on the product in the ABS Records as of the date and time the certificate is printed.

If the Rules and/or standards used in the PDA evaluation are revised or if there is a design modification (whichever occurs first), a PDA revalidation may be necessary.

The continued validity of the MA is dependent on completion of satisfactory audits as required by the ABS Rules. The validity of both PDA and MA entitles the product to receive a **Confirmation of Product Type Approval**.

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or prior to the effective date of the ABS Rules and standards applied at the time of PDA issuance. ABS makes no representations regarding Type Approval of the Product for use on vessels, MODUs or facilities built after the date of the ABS Rules used for

this evaluation.

Type Approval requires Drawing Assessment, Prototype Testing and assessment of the manufacturer's quality assurance and quality control arrangements. The manufacturer is responsible to maintain compliance with all specifications applicable to the product design assessment. Unless specifically indicated in the description of the product, certification under type approval does not waive requirements for witnessed inspection or additional survey for product use on a vessel, MODU or facility intended to be ABS classed or that is presently in class with ABS.

Due to wide variety of specifications used in the products ABS has evaluated for Type Approval, it is part of our contract that; whether the standard is an ABS Rule or a non-ABS Rule, the Client has full responsibility for continued compliance with the standard.

Questions regarding the validity of ABS Rules or the need for supplemental testing or inspection of such products should, in all cases, be addressed to ABS.