



TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MERB0000452
Revision No:
0

This Certificate is issued by DNV UK Limited based on authorisation of the Maritime & Coast Guard Agency (MCA) as an UK Approved Body to undertake conformity assessments on marine equipment in accordance with the requirements of the Merchant Shipping (Marine Equipment) Regulations 2016 as amended.

This is to certify:

That the Penetrations through "A" class divisions: pipe, duct, trunk, etc penetrations

with type designation(s)

Roxtec sealing system with multidiameter technology: SE PPS S-series (steel)

Issued to

Roxtec International AB
Karlskrona, Sweden

is found to comply with the requirements in the following Regulations/Standards:

Regulation **MSN 1874 Amendment 6,**

item No. UK/3.26b. SOLAS 74 as amended, Regulation II-2/9, IMO MSC.1/Circ.1276 and IMO 2010 FTP Code

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2023-06-13**.

Issued at **London** on **2022-11-30**

DNV local unit:
Gothenburg

Approval Engineer:
Roland Priebe



Approved Body No.: **0097**

for **DNV UK Ltd.**

Christine Mydlak-Röder
MER Service Responsible



**Maritime &
Coastguard
Agency**

UK Approved Body Authorised
by the MCA

The Mark of Conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-control phase module (D, E or F) of Schedule 2 of the Merchant Shipping (Marine Equipment) Regulations 2016, as amended is fully complied with and controlled by a written inspection agreement with an approved body. The product liability rests with the manufacturer or his representative in accordance with the Merchant Shipping (Marine Equipment) Regulations 2016.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV UK Ltd. of any changes to the approved equipment. Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply. This certificate remains valid unless suspended, withdrawn, re-called, or cancelled.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

“Roxtec sealing system with multidiameter technology: SE PPS S-series (steel)”
 consisting of Roxtec S-series steel frames (S, SO, SF, SFO, SR, SK, SRC r20 and SRC r40) in sizes 2-6, and combinations thereof up to x4, to be used together with SE PPS extension frames, bolted or welded to the steel sections. The extension frame is equipped with intumescent material strips. The S frame is filled with Roxtec (standard or EMC) halogen free RM modules. Assembled with Roxtec Wedge kit or Roxtec EMC Wedge kit.

Application/Limitation

Approved for use as a penetration system in class A-0, A-15, A-30 and A-60 steel bulkheads and decks for approved pipes and cables as follows:

Type of Pipe	Dia. pipe [mm]	S-series size	Deck/Bulkhead
Thermoplastic (PP, PVC, PB, ABS, HDPE, PVDF)	16-99	2-6	Deck/Bulkhead
PE/Alu flexi pipe	16-99	2-6	Deck/Bulkhead
Copper and steel pipes	10-54	2-6	Deck
Approved ships cables	Up to 60	1-6	Deck/Bulkhead

Deck or bulkhead to be insulated with approved insulation according to classification covering the edge of the steel frame. See insulation drawing specified in the Type Examination Documentation.

The insulation materials used have to be approved according to the UK Marine Equipment Regulation and bear the Mark of Conformity.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Test Reports Nos.:

- 103070.27A (A-60 bulkhead) and 103070.27B (A-60 deck) both dated 4 July 2003 from SINTEF, Norway
- P701755 dated 12 June 2007 from SP, Sweden
- 09-344E dated 2011-12-09 (A-60 bulkhead, Reference test for SRC-frame; Transit D) from RIME, Japan

Assessment No.103201.33 dated 11 September 2003 from SINTEF, Norway.

Drawing No. S1015479 dated 3 November 2008 from Roxtec International AB.

Tests carried out

Tested according to IMO FTP Code Part 3 and in accordance with IMO 2010 FTP Code Ch. 8.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, fire-technical rating and the Mark of Conformity (see page 1).

Additional application/information for watertightness/gastightness (Not part of the UK Marine Equipment Regulation requirement)

Product description

"Roxtec sealing system with multidiameter technology: SE PPS S-series (steel)"
consisting of Roxtec S-series steel frames (S, SO, SF, SFO, SR, SK, SRC r20 and SRC r40) in sizes 2-6, and combinations thereof up to x4, to be used together with PPSE extension frames, bolted or welded to the steel sections. The extension frame is equipped with intumescent material strips. The S frame is filled with Roxtec (standard or EMC) halogen free RM modules. Assembled with Roxtec Wedge kit or Roxtec EMC Wedge kit.

Application/Limitation

Approved for penetration of plastic pipes and cables in steel bulkheads or decks and for copper and steel pipes in steel deck limited to a pressure of 4 bar watertightness and 2.67 bar gastightness.

For bolted versions with gasket and self-tapping screws, the pressure is limited to 3.3 bar watertightness and 1.7 bar gastightness.

The penetration system is not to be used for penetrating boundaries of tanks.

When requested to be used in watertight bulkheads on passenger ships and Special Purpose Ships (SPS), the penetration system has to comply with the requirements given in SOLAS Ch. II-1 Reg. 13.2.3 (2009 issue). Penetrations passing through watertight bulkheads are subject for separate examination and approval (water tightness after a standard fire test). This product has not been tested according to Reg. 13.2.3.

Type Approval documentation

Test reports No. MLM 020401 dated 25 March 2002 from DNV Malmö (screws), MLM020133 dated 26 February 2002 (steel pipes), MLM0504010 dated 20 May 2005 (Copper pipes) from DNV Malmø and No. SKM-04-4088 dated 16 June 2004 from DNV Stockholm.

Inspection report No. MLM 020408 dated 3 June 2002 from DNV Malmö.

Tests carried out

Pressure test with water and Helium according to DNV Type Approval Programme 8.471.19-1.