



TYPE APPROVAL CERTIFICATE
No. LAB498522CS/005

This is to certify that the product identified below is in compliance with the regulations herewith specified.

<i>Description</i>	Devices for the passage of pipes through A or B Class divisions
<i>Type</i>	Roxtec RS Series
<i>Applicant</i>	ROXTEC INTERNATIONAL AB ROMBVAGEN 2, P.O. BOX 540 SE-37123 KARLSKRONA SWEDEN
<i>Manufacturer</i>	ROXTEC INTERNATIONAL AB
<i>Place of manufacture</i>	ROMBVAGEN 2, 37165 LYCKEBY SWEDEN
<i>Reference standards</i>	IMO Res. MSC.307(88)-(2010 FTP Code)

Issued in Genoa on June 5, 2023. This Certificate is valid until February 7, 2028

RINA Services S.p.A.

Enrico Cabella

This certificate consists of this page and 1 enclosure

TYPE APPROVAL CERTIFICATENo. **LAB498522CS/005**

Enclosure - Page 1 of 6

Roxtec RS Series

Product description

Devices, composed of halogen free material packing system, for the passage of pipes having diameter ranging from 6 up to 330 mm through A Class aluminium and steel bulkheads and decks. The aluminium bulkheads and decks are insulated by means of two layers of mineral wool with aluminium foil (certified non-combustible according to the IMO FTP Code), having, each, minimum thickness of 30 mm and minimum density of 130 kg/m³ on the exposed side (decks) and on both sides (bulkhead). The steel bulkheads and decks are insulated with different configuration described in the following tables. The division insulation covers also the transits and is applied all around the same for a minimum width of 250 mm; the transits that may be fitted with additional insulation (certified non-combustible according to the IMO FTP Code) as described in the following tables:

ALUMINIUM DIVISIONS**BULKHEADS - METALLIC PIPES**

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
From RS 23 up to RS 75	Metallic pipes – diameter from 8 up to 28 mm	Mineral wool cylinder, one layer 50 mm thick having density of 100 kg/m ³ and length of 250 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.
From RS 27 up to RS 100	Metallic pipes – diameter greater than 28 up to 57 mm	Mineral wool cylinder, one layer 50 mm thick having density of 100 kg/m ³ and length of 300 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.
From RS 100 up to RS 150	Metallic pipes – diameter greater than 57 up to 108 mm	Mineral wool cylinder, one layer 50 mm thick having density of 100 kg/m ³ and length of 600 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.

TYPE APPROVAL CERTIFICATE**No. LAB498522CS/005****Enclosure - Page 2 of 6****DECKS - METALLIC PIPES**

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
From RS 23 up to RS 75	Metallic pipes – diameter greater than 8 up to 28 mm	Mineral wool cylinder, with steel net - one layer 50 mm thick having density of 100 kg/m ³ and length of 300 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
From RS 75 up to RS 100	Metallic pipes – diameter greater than 28 up to 57 mm	Mineral wool cylinder, with steel net - one layer 50 mm thick having density of 100 kg/m ³ and length of 400 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
From RS 100 up to RS 150	Metallic pipes – diameter greater than 57 up to 108 mm	Mineral wool cylinder, with steel net - one layer 50 mm thick having density of 100 kg/m ³ and length of 600 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.

DECKS - FIBERGLASS PIPES

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
From RS 68 up to RS 125	Fiberglass – diameter from 32 up to 90 mm	Mineral wool cylinder, with steel net - one layer 50 mm thick having density of 100 kg/m ³ and length of 200 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.

TYPE APPROVAL CERTIFICATE

No. LAB498522CS/005

Enclosure - Page 3 of 6

STEEL DIVISIONS

BULKHEADS - insulated by means of two layers of mineral wool (certified non-combustible according to the IMO FTP Code) having minimum thickness of 50 and 30 mm and minimum density of 100 kg/m³ – METALLIC PIPES

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
RS 25	steel pipes – diameter 6 mm	No additional insulation	The penetration is fixed to the bulkhead plate in the middle.
From RS 25 up to RS 50	Steel pipes – diameter greater than 6 up to 28 mm	Mineral wool cylinder, with steel net - one layer 60 mm thick having density of 100 kg/m ³ and length of 300 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.
From RS 50 up to RS 400	Metallic pipes – diameter greater than 28 up to 330 mm	Mineral wool cylinder, one layer 100 mm thick having density of 100 kg/m ³ and length of 1200 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.
RS 50	Copper pipes – diameter 28 mm	Mineral wool cylinder, one layer 50 mm thick having density of 100 kg/m ³ and length of 500 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.

BULKHEADS - insulated by means of two layers of mineral wool (certified non-combustible according to the IMO FTP Code) having, each, minimum thickness of 50 mm and minimum density of 200 kg/m³ – METALLIC PIPES

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
RS 23	Steel pipes – diameter 10 mm	Mineral wool cylinder - one layer 50 mm thick having density of 100 kg/m ³ and length of 300 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.
RS 23	Copper pipes – diameter 6 mm	Mineral wool cylinder - one layer 50 mm thick having density of 100 kg/m ³ and length of 300 mm	The penetration is fixed to the bulkhead plate in the middle; the additional insulation is fitted on the unexposed side.

TYPE APPROVAL CERTIFICATE**No. LAB498522CS/005****Enclosure - Page 4 of 6**

DECKS - insulated by means of two layers of ceramic wool (certified non-combustible according to the IMO FTP Code) having, each, minimum thickness of 25 mm and minimum density of 96 kg/m³ – METALLIC PIPES

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
From RS 23 up to RS 50	Steel pipes – diameter from 8 up to 28 mm	Ceramic wool cylinder - four layers 25 mm thick each having density of 96 kg/m ³ and length of 400 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
From RS 50 up to RS 150	Steel pipes – diameter greater than 28 up to 114.3 mm	Ceramic wool cylinder - four layers 25 mm thick each having density of 96 kg/m ³ and length of 600 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
From RS 50 up to RS 150	Steel pipes – diameter greater than 28 up to 114.3 mm	Ceramic wool cylinder - four layers 25 mm thick each having density of 96 kg/m ³ and length of 400 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on both sides.

TYPE APPROVAL CERTIFICATE

No. LAB498522CS/005

Enclosure - Page 5 of 6

DECKS - insulated by means of two layers of mineral wool (certified non-combustible according to the IMO FTP Code) having minimum thickness of 50 and 30 mm and minimum density of 125 kg/m³ – METALLIC PIPES

TYPE OF TRANSITS	TYPE OF PIPES	ADDITIONAL INSULATION	TRANSIT FIXING AND NOTES
RS 23	Steel pipes – diameter 10 mm	Mineral wool cylinder - two layers 25 mm thick each having density of 100 kg/m ³ and length of 300 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
From RS 23 up to RS 150	Steel pipes – diameter greater than 10 up to 108 mm	Mineral wool cylinder - two layers 25 mm thick each having density of 100 kg/m ³ and length of 450 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
RS 23	copper pipes – diameter 6 mm	Mineral wool cylinder - two layers 25 mm thick each having density of 100 kg/m ³ and length of 300 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.
From RS 23 up to RS 150	Copper pipes – diameter greater than 6 up to 108 mm	Mineral wool cylinder - two layers 25 mm thick each having density of 100 kg/m ³ and length of 600 mm	The penetration may be fixed to the deck plate in the middle, exposed or unexposed side; the additional insulation is fitted on the exposed side.

TYPE APPROVAL CERTIFICATE

No. LAB498522CS/005

Enclosure - Page 6 of 6

Field of application

Fire resistant A-60 Class pipe penetrations through steel and load-bearing aluminium bulkheads and decks.

Reference documents

Roxtec drawings enclosed in DANAK Test Reports No. PG11955 and No. PG11898 dated 17 April 2009, RIME Test reports No. 09-345 and No. 09-346 dated 11 December 2009 and SP Test Report No. 4P06068 dated 17 January 2015.

Tests carried out

Tests as per DANAK Test Reports No. PG11955 and No. PG11898 dated 17 April 2009, RIME Test reports No. 09-345 and No. 09-346 dated 11 December 2009 issued according to IMO Res. A.754 (18) and SP Test Report No. 4P06068 dated 17 January 2015 issued according to IMO 2010 FTP Code.

General conditions for the approval

- a) The initial conditions verified by RINA at the time of the approval are to be maintained
- b) Any changes to the initial conditions are to be promptly communicated to RINA, which reserves the right to repeat the relevant assessment
- c) This certificate will no be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with RINA
- d) RINA personnel are to allowed to witness during the performances of activities, upon their request
- e) The activities are to be carried out in compliance with the RINA Rules and/or other applicable Rules
- f) Should the specified regulations or standards be amended during the validity of this certificate, the product is to be reapproved prior to it being placed on board vessels to which the amended regulations or standards apply.

Genoa 5/06/2023

File Allegato/Attached file