


TYPE	ROWS [QTY]	H1 [mm]	H2 FOR +SINGLE FRAMES [mm]	H2 FOR +COMB. FRAMES [mm]
S 2+2xN	2	101	232	242
S 4+4xN	2	159.5	349	359
S 6+6xN	2	218	466	476
S 8+8xN	2	278	586	596
S 2+2+2xN	3	101	343	363
S 4+4+4xN	3	159.5	518.5	538.5
S 6+6+6xN	3	218	694	714
S 8+8+8xN	3	278	874	894
S 2+2+2+2xN	4	101	454	484
S 4+4+4+4xN	4	159.5	688	718
S 6+6+6+6xN	4	218	922	952
S 8+8+8+8xN	4	278	1162	1192


N [QTY]	TYPE	W [mm]	T [mm]
x1	+SINGLE	140.5	10
x2	+COMB.	271	20
x3	+COMB.	401.5	20
x4	+COMB.	532	20
x5	+COMB.	662.5	20
x6	+COMB.	793	20
x7	+COMB.	923.5	20
x8	+COMB.	1054	20
x9	+COMB.	1184.5	20
x10	+COMB.	1315	20

N: FRAME OPENINGS/ROW



S 8+8x1
N=1





S 8+8x3
N=3



S 8+8+8x4
N=4



F		2024-11-07	se-marfre
Rev	Type of revision	Date	Sign

General tolerances used for manufacturing shown in document DOC-002180		Designed by/date se-luckri 2003-11-03	Latest save date 2024-11-07	Format A3	Scale	Sheet no 1 / 1	TotWeight
 www.roxtec.com		Title S FRAME +SINGLE AND +COMBINATION FRAME			Projection method 		Rev F
		Restricted due to Information drawing		Drawing number S1005523			