


格克赛克保留所有权利。未经授权严禁复制，使用以及向第三方泄露。

All rights reserved. Unauthorized reproduction, use or disclosure to third parties is strictly forbidden.

SIZE	A (mm)	STEEL PIPE END B (mm)	PLASTIC PIPE END C (mm)	INTUMESCENT SIZE	INTUMESCENT NO OF LAYERS
SLEEV-IT TR - MAR50/50	70	54	54	60x1.8	3
SLEEV-IT TR - MAR50/60 (2")	80	54	64	60x2.5	3
SLEEV-IT TR - MAR75/75	101	78	78	60x2.5	4
SLEEV-IT TR - MAR75/90 (3")	115	79	93	60x2.5	4
SLEEV-IT TR - MAR90/90	118	94	93	60x2.5	4



ITE	QTY	Designation	Specification	Weight
4	-	JUBILEE CLIP	STAINLESS STEEL	0
3	-	PIPE HOLDER	STAINLESS STEEL	0
2	-	INTUMESCENT MATERIAL		0
1	-	TRANSITION COLLAR	STAINLESS STEEL	0

ROXTEC INTERNATIONAL AB BOX 540 S-371 23 Karlskrona TEL: +46 455 366700 FAX: +46 455 82012	Designed by se-ronpet	Designed Date 2012-02-03	General tolerance ISO 2788-1/2-m/K EN ISO 13920-BF	Welded details EN ISO 5817-B EN ISO 10042-B	General surface roughness, Ra 12.5	TotWeight
	Approved by se-tonfor	Approved Date 2013-01-07	Title TRANSITION COLLAR ASSEMBLY			Projection method
	Format A3	Scale 1:-	Drawing number S1026334		Rev B	

B	NO OF LAYERS ADDED	2013-01-07	se-ronpet
Rev	Type of revision	Date	Sign